



TOWN OF COLLIERVILLE
GENERAL SERVICES DEPARTMENT
Procurement Division
MEMORANDUM



TO: ALL TC2017-27 ELEVATED TANK PAINTING
FROM: MANDY BAJUSZ, PROCUREMENT MANAGER
SUBJECT: ADDENDUM #1
DATE: 11/9/2017
CC: TC2017-27 FILE

A D D E N D U M N O. 1

Vendor shall acknowledge receipt of this Addendum #1 consisting of 1 pages by signing and dating below. Please fax back to (901) 457-2258 or email a scanned copy to tocpurchasing@ci.collierville.tn.us.

Company Name

Date

The information below regarding bid TC2017-27, Elevated Tank Painting is being provided to supplement and clarify the information provided within the bid documents.

1. All paint must meet the specifications provided in Section 01020, Elevated Tank Work, Part 1, 1.01 (A) of bid document. No particular brand/manufacturer has been specified; however, the contractor will be required to submit this information for review prior to contract award.
2. All coatings in contact with potable water or applied to the inside area of the tank shall be listed by NSF International (National Sanitation Foundation) or UL under ANSI/NSF Standard 61, Section 5, Protective (Barrier) Materials, Potable Water Tank Coatings.